


THIS IS NOT A PERMIT



25 OCT 2016 RCU

## New York State Department of Environmental Conservation Notice of Complete Application

*Date:* 10/20/2016

*Applicant:* VILLAGE OF ROCKVILLE CENTRE  
PO BOX 950  
ROCKVILLE CENTRE, NY 11571-0950

*Facility:* ROCKVILLE CENTRE POWER PLANT  
110 MAPLE AVE  
ROCKVILLE CTR, NY 11571

*Application ID:* 1-2820-00753/00008

*Permits(s) Applied for:* 1 - Article 19 Air Title V Facility

*Project is located:* in HEMPSTEAD in NASSAU COUNTY

*Project Description:*

The Department has prepared a draft permit and has made a tentative determination to issue a Permit Modification for the following project: This project involves removal of the old silencers and stacks on Diesel Generator #9 and #10 and installation of new silencers and stacks on Diesel Generators #9 & #10 with Catalyst CO Oxidation System. The Power Plant is part of a small municipal not for profit facility that supplies electricity to residents, businesses, health care facilities and municipal government entities within the Village of Rockville Centre. As a "peak shaver" it gets most of its power from the grid and generates electricity as the power demand dictates. The Power Plant consists of eight diesel engine-generators with differing capacities and fuel capacities, together with supporting equipment. The diesel engine-generators are designated as units #7, #8, #9, #10, #11, #12, #13, and #14. Units #7, #8 and #12 are designated as emergency generators.

In accordance with 6NYCRR Parts 621.7(b)(9) and 201-6.3(c), the Administrator of the United States Environmental Protection Agency (USEPA) has the authority to bar issuance of any Title V Facility Permit if it is determined not to be in compliance with applicable requirements of the Clean Air Act or 6NYCRR Part 201.

Persons wishing to inspect the subject Title V files, including the application with all relevant supporting materials, the draft permit, and all other materials available to the DEC (the "permitting authority") that are relevant to this permitting decision should contact the DEC representative listed below. The Draft Permit and Permit Review Report may be viewed and printed from the Department web site at:

<http://www.dec.ny.gov/chemical/32249.html>.

DEC will evaluate the application and the comments received on it to determine whether to hold a public hearing. Comments and requests for a public hearing should be in writing and addressed to the Department representative listed below. A copy of the Department's permit hearing procedures is available upon request or on the Department web site at: <http://www.dec.ny.gov/permits/6234.html>.

*Availability of Application Documents:*

Filed application documents, and Department draft permits where applicable, are available for inspection during normal business hours at the address of the contact person. To ensure timely service at the time of inspection, it is recommended that an appointment be made with the contact person.

*State Environmental Quality Review (SEQR) Determination*

Project is not subject to SEQR because it is a Type II action.

*SEQR Lead Agency* None Designated

*State Historic Preservation Act (SHPA) Determination*

The proposed activity is not subject to review in accordance with SHPA. The application type is exempt and/or the project involves the continuation of an existing operational activity.

*DEC Commissioner Policy 29, Environmental Justice and Permitting (CP-29)*

It has been determined that the proposed action is not subject to CP-29.

*Availability For Public Comment*

Comments on this project must be submitted in writing to the Contact Person no later than 12/02/2016 or 30 days after the publication date of this notice, whichever is later.

*Contact Person*

SUSAN ACKERMAN  
NYSDEC  
SUNY @ Stony Brook|50 Circle Rd  
Stony Brook, NY 11790-3409  
(631) 444-0357

---

**CC List for Complete Notice**

ENB

C. Anyaebunam

S. Bwa - EPA

Conn-DEP

NJ-DEP